

FALSE DEAD END



The False Dead End are used to brace distribution lines, telecommunication lines and antenna towers. They are produced in standard dimensions of ½ inch or less and in conformity with the ASTM A.475 or the CSA G12 standards. The False Dead Ends and the guys must have the same (left hand) direction. The guy end reaches its maximum tension capacity if the cable is made according to the standard (ASTM A-475 / CSA-G12) grade 180 specifications. During its initial installation, a maximum of three times the guy end may be removed or replaced. However, should a problem arise after more than three months of use, a change is necessary. This product is produced in class A steel, class B or GALFAN grade 180 (CSA-G12 / ASTM-A475) standard.

availa ZINC A coated = **FGNA**
 ZINC B coated = **FGNB**
 GALFAN = **FGNG**

Here is a guide to understanding the catalog number. It is divided into 3 parts, ex: **1/4-36-FGNG** , **1/4** is the diameter of the strand, **36** is the length in inches and **FGNG** is for "False dead ends", ex 1/4-36-FGN, A, B or G is the coating.

STRAND		CATALOG		DESCRIPTION		
Diameter±		PAYER code	Reference	Packaging	length± Inch	Color
1/4	3w,7w	1/4-36-FGNx	BFDE-9121	50	36	Yellow
5/16	3w, 7w	5/16-39-FGNx	BFDE-9123	50	39	Black
3/8	3w, 7w	3/8-42-FGNx	BFDE-9124	40	42	Orange
7/16	7w	7/16-48-FGNx	BFDE-9125	25	48	Green
1/2	7w, 19w	1/2-50-FGNx	BFDE-9126	15	50	Blue